

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 03/कम्य ई. प्र. 03

Dated: 18.08.26

It is certified that an inspection team headed by MANAJ KUMAR, ASSISTANT RESEARCH (Name OFFICER

of Officers with designation) from U.P. JAL NIGAM (RURAL) PHED inspected the

SAMRAT ASHOK MAHAN PUBLIC SCHOOL, MATHURA U.P. (Name & Address of the school)
PARANDEEH, GARAPUR, PRAYAGRAJ

on 18.08.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing

no. CHEMICAL TEST/5450/2026-27

dated 18.08.2026

of

REGIONAL WATER ANALYSIS LABORATORY, U.P. JAL NIGAM (RURAL) PRAYAGRAJ.

U.P. (PHED Lab) certified that

the SAMRAT ASHOK MAHAN PUBLIC SCHOOL (Name of school) has safe drinking

water facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 YEAR

सहायक शोध अधिकारी
क्षेत्रीय जल परीक्षण प्रयोगशाला
खण्ड कार्यालय

Signature with Seal: उ.प्र. जल निगम (ग्राम) प्रयागराज

Name :

Designation :

Name & Address of the Office / Department :

To
SAMRAT ASHOK MAHAN PUBLIC
SCHOOL, MATHURA U.P., PARANDEEH
(Name & Address of the Institution) GARAPUR, PRAYAGRAJ.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Water Analysis Report
Regional Water Analysis Laboratory,
Khand Karyalaya, U.P. Jal Nigam, (Rural) Tulapur Pani ki Tanki, Jhansi,
Prayagraj - 211019
"Test Report"

Report No- Chemical Test/ 5450/2026-27		Date- 18-08-2026		Temperature- 22° c		Humidity- 44%	
Customer details							
Office Name and Address		Samrat Ashok Mahan Public School, Mathura urf Parandeeh, Garapur, Prayagraj					
Ref Letter No & Date				Contact No.		9616494098	
Basic Details of Sample							
District		Prayagraj		Block		Sahson	
Gram Panchayat		Beruic		Village		Mathura urf Parandeeh	
Habitation				Location		Samrat Ashok Mahan Public School	
Type of Source		RO water		Sample No		26085450	
Quantity of Sample		Normal 1000(ml)		Date of S.C.		07-08-2026	
Receiving Date		07-08-2026		S. Collector		Sample not withdrawn by lab	
Ref. Method of Sampling		IS 3025 (Part 1): 1987		Contact No.			
Analysis Start Date		11-08-2026		Analysis Completion date		12-08-2026	
Technical data of analysis							
S.No	Analysed parameters	Observed Value	Specification as per IS 10500:2012		Ref. Method of Analysis		
			Acceptable Limit	Permissible limit			
1	2	3	4	5	6		
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023		
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018		
3	Colour (HU)	BDL	5	15	APHA 24th Ed., 2023, 2120-color-B, (Visual Color Comparison Method)		
4	pH at (25° C)	8.01	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022 (Electrometric Method)		
5	Turbidity (NTU)	3.71	1	5	IS 3025 (Part 10): 2023 (Nephelometric Method)		
6	Total Dissolved Solids (mg/l) at (180° C)	102.7	500	2000	IS 3025 (Part 16): 2023 (Gravimetric Method)		
7	Chloride (mg/l)	24	250	1000	IS 3025 (Part 32): 2025 (Argentometric method)		
8	Total Alkalinity (as CaCO ₃) (mg/l)	48	200	600	IS 3025 (Part 23): 2023 (Titration Method)		
9	Total Hardness (as CaCO ₃)(mg/l)	60	200	600	IS 3025 (Part 21): 2023 (EDTA Titrimetric Method)		
10	Calcium (as Ca) (mg/l)	16.03	75	200	IS 3025 (Part 40): 2024 (EDTA Titrimetric Method)		
11	Magnesium (as Mg) (mg/l)	4.89	30	100	IS 3025 (Part 46): 2023		
12	Sulphate (mg/l)	44.61	30	400	APHA 24th Ed., 2023, 4500-SO ₄ -E (Turbidimetric Method)		
13	Nitrate (mg/l)	14.28	45	No relaxation	APHA 24th Ed. 2023. 4500-NO ₃ -B (Ultraviolet Spectrophotometric Screening Method)		
14	Fluoride (mg/l)	NT	1	1.5	APHA 24th Ed., 2023. 4500-F-C (Ion Selective Electrode Method)		
15	Iron (mg/l)	0.18	1	No relaxation	APHA 24th Ed., 2023. 3500-Fe-B (Phenanthroline Method)		
BDL-Below Detection Limit, NT- Not Tested							
Note 1. This certificate refers only to the particular sample(s) submitted for testing. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory. 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements. 4. Sample will be stored up to 07 days from the date of issue of test reports unless otherwise specified.							
							
Prepared by		Reviewed by		Authorized Signatory			
Laboratory Contact detail-Email-labprayagraj@gmail.com				Mob-7307766359			

*****END OF THE REPORT*****





Water Analysis Report
Regional Water Analysis Laboratory,
Khand Karyalaya, U.P. Jal Nigam,(Rural) Tulapur Pani ki Tanki, Jhunsi,
Prayagraj - 211019
Test Report

Report No- Bacteriological Test/5450/2026-27	Date-18-08-2026	Temperature- 22° c	Humidity- 44%
--	-----------------	--------------------	---------------

Customer details

Office Name and Address	Samrat Ashok Mahan Public School, Mathura urf Parandeh., Garapur, Prayagraj		
Ref Letter No & Date	Contact No.	9616494098	

Basic Details of Sample

District	Prayagraj	Block	Sahson
Gram Panchayat	Beruic	Village	Mathura urf Parandeh
Habitation		Location	Samrat Ashok Mahan Public School
Type of Source	RO water	Sample No	26085450
Quantity of Sample	Normal 1000(ml)	Date of S.C.	07-08-2026
Receiving Date	07-08-2026	S. Collector	Sample not withdrawn by lab
Ref. Method of Sampling	IS 3025 (Part 1): 1987	Contact No.	
Analysis Start Date	11-08-2026	Analysis Completion date	12-08-2026

S.No	Analysed parameters	Observed Value	Unit of Measurment	Specification as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Total Coliform (Bacteria)	0	CFU/100ml.	Shall Not be Detectable 100 ml Sample	0	APHA 24th-2023,9010
2	E. Coliform	0	CFU/100ml.	Shall Not be Detectable 100 ml Sample	No relaxation	APHA 24th-2023,9010
3	Free Residual Chlorine (mg/l)	0.1	mg/l	0.2	0.2	IS 3025 (Part-26):2021

BDL-Below Detection Limit, NT- Not Tested

- Note**
1. This certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 15 days from the date of issue of test reports unless otherwise specified.

Report Prepared by

Nethy
lab in charge

Laboratory Contact detail-Email-labprayagraj@gmail.com

***** END OF THE REPORT *****

